

Marquee Heating Requirements

		Mid Winter Night	Mid Winter Day	Spring	Autumn	Summer
Wall Height M	Floor Area M ²	kW/hr at -1 °C External	kW/hr at +5 °C External	kW/hr at +7 °C External	kW/hr at +10 °C External	kW/hr at +13 °C External
2.4	25	15	11	10	8	6
2.4	50	24	18	16	13	10
2.4	75	34	26	23	18	14
2.4	100	40	30	26	21	16
2.4	150	55	41	36	29	22
2.4	200	70	52	46	37	28
3	25	17	13	12	9	7
3	50	29	22	19	16	12
3	75	41	30	27	22	16
3	100	47	35	30	25	19
3	150	65	48	42	34	26
3	200	83	61	54	43	33
4	25	22	17	15	12	9
4	50	37	28	24	20	15
4	75	52	38	34	27	21
4	100	59	44	39	31	23
4	150	81	60	53	42	32
4	200	103	76	67	54	40
5	25	27	20	18	14	11
5	50	45	33	29	24	18
5	75	62	46	41	33	25
5	100	71	52	46	37	28
5	150	97	72	63	51	38
5	200	123	91	80	64	48